



Lloyd's
Register

Notified Body authorised by the MCA



Maritime &
Coastguard
Agency

EC TYPE EXAMINATION (MODULE B) CERTIFICATE

This is to certify that:

LLOYD'S REGISTER VERIFICATION LIMITED (LRV), specified as a "notified body" under the terms of The Merchant Shipping (Marine Equipment) Regulations S.I. 1999 No. 1957, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the essential Fire protection requirements of Marine Equipment Directive (MED) 96/98/EC as modified by Commission Directives 98/85/EC, 2001/53/EC, 2002/75/EC, 2002/84/EC, 2008/67/EC, 2009/26/EC, 2010/68/EU, 2011/75/EU, 2012/32/EU, 2013/52/EU, 2014/93/EU and 2015/559 subject to any conditions in the Design Appraisal Document attached hereto.

Manufacturer Raccorderie Metalliche S.p.A.

Address Strada sabbionetana 59
46010 Campitello di Marcaria (MN)
Italy

Annex A1 Item A.1/3.26b PENETRATIONS THROUGH 'A' CLASS DIVISIONS - PIPE, DUCT, TRUNK ETC PENETRATIONS

Product Type PIPE PENETRATION (STANDARD FIRE TEST)

Product Description Single Metallic Pipe Penetration – Type: "RM INOXPRESS" for applications in A- Class steel bulkheads and decks

Specified Standard IMO Res. MSC.307(88) 2010 FTP Code, Annex 1, Part 3

The attached Design Appraisal Document (schedule) forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Date of issue 23 June 2016 Expiry date 22 June 2021

Certificate No. MED 1650182

Signed



Sheet No. 1 of 4


Name

M. Farrier

For and on behalf of Lloyd's Register Verification
LRV EC Distinguishing No. 0038

Note:

This certificate is not valid for equipment; the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify the notified body named on this certificate of any modification or changes to the equipment in order to obtain a valid Certificate.



0038/yy

Subject to compliance with the conditions in the attached Design Appraisal Document (schedule), which forms part of this certificate, and those of Articles 10.1(i) and 11 of the Directive, the Manufacturer is allowed to affix the "Mark of Conformity" to the Product described herein.
yy Last two digits of year mark affixed.

This certificate is issued under the authority of the MCA.

Lloyd's Register Verification Limited (Reg. no. 4929226) is a limited company registered in England and Wales. Registered office: 71 Fenchurch Street, London, EC3M 4BS, UK.
A subsidiary of Lloyd's Register Group Limited.

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page	2 of 4
Document number	MED 1650182
Issue number	1

DESIGN APPRAISAL DOCUMENT

Date 13 July 2016	Quote this reference on all future communications SOUTSO/SFS/TA/TR/MF/WP25988771
----------------------	---

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1650182

The undernoted documents have been appraised for compliance with the relevant requirements of International Conventions and European Union legislation for the EC Type Examination of Marine Equipment for use on Merchant Ships Registered in the European Economic Area.

This Design Appraisal Document (schedule) forms part of the Certificate.

APPROVAL DOCUMENTATION

Materials Research Centre for Fire Resistance and Protection, C.S.N.I. Sc.a.r.I. Divisione LAB, Genova, Italy, Test Reports No. 512112A16/1 Issue 01 dated 2 March 2016, No. 611092A16/1 Issue 01 dated 2 March 2016

Manufacturers Technical Handbook January 2015

CONDITIONS OF CERTIFICATION

1. For use in conjunction with A-60 steel bulkheads and decks with an A-60 approved insulation arrangement, suitable for the fire rating of the division. For applications in A-0, A-15 or A-30 Class bulkheads and decks, the penetrations and pipes shall be fitted with A-60 insulation arrangements as-tested, on the penetration itself (including any pipe insulation) on both sides of the division, and for a minimum of 200mm around the penetration on the plate, on the underside of decks and on both sides of bulkheads
2. Pipe penetration type "RM INOXPRES" consists of: stainless steel pipe fitting with an outer steel sleeve/coaming 120mm long, fixed to middle of a D1 15 to D1 108 O.D. stainless steel pipe fitting (450mm long), with the sleeve welded to the bulkhead or deck. Pipe fittings are connected to stainless steel pipes of same diameter with push-fit socket couplings. Each coupling set fitted in fire tests were protected by pipe insulation sections and fitted with a ring gasket, type: EPDM
3. Further details of approved penetrations and insulation arrangements in bulkheads and decks are as described in Tables 1 and 2 below. In all cases, the total insulated length includes the insulation fitted on the plate on both sides of the bulkhead or deck. The type of insulation applied on the bulkhead and deck was "PAROC Marine Fire Slab 100" (100kg/m³ density, 60mm thick bulkhead and 40mm thick deck) preformed sections and an equivalent approved insulation system may be accepted. A slab of the same insulation 300mm x 300mm was fitted around the penetration and was applied to the plate on the non-insulated side of the division. The type of insulation applied to the pipework was "PAROC Pro Section 140" (140kg/m³ density, 50mm thick) and an equivalent approved insulation system may be accepted. The insulation length fitted on the pipe and penetration was measured from the face of the bulkhead or deck and was fitted on both sides of the division and fully covered the EPDM seals and all pipe joints
4. Penetrations are to be separately approved by the Administration for the type of pipe services and their operating pressures, on a case by case basis
5. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page 3 of 4
Document number MED 1650182
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 13 July 2016	Quote this reference on all future communications SOUTSO/SFS/TA/TR/MF/WP25988771
----------------------	---

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1650182

- Production items of the subject equipment are to be manufactured in accordance with either an approved Production Quality Assurance system (Module D), a Product-Quality assurance system (Module E) or a Product Verification Process (Module F). The wheelmark cannot be affixed to the product until a conformity assessment module is in place
- Each item, batch or lot of the equipment is to be issued with a "Declaration of Conformity" and have the "Mark of Conformity" affixed after a conformity assessment module is in place

TABLE 1
APPROVED ARRANGEMENTS IN STEEL BULKHEADS

Pipe Penetration Type	Nominal Pipe Dia. "D1" (mm)	Fire Rating	Penetration length (mm)	Pipe coaming thickness (mm)	Total Insulated Length for Bulkhead (mm)	Description of penetration
RM INOXPRES Type D1 Stainless Steel	15mm	A-60	450	4.0	740	Straight pipe with welded mid flange connection to division.
RM INOXPRES Type D1 Stainless Steel	108mm	A-60	450	10.5	940	Straight pipe with welded mid flange connection to division.

TABLE 2
APPROVED ARRANGEMENTS IN STEEL DECKS

Pipe Penetration Type	Nominal Pipe Dia. "D1" (mm)	Fire Rating	Penetration length (mm)	Pipe coaming thickness (mm)	Total Insulated Length for Deck (mm)	Description of penetration
RM INOXPRES Type D1 Stainless Steel	15mm	A-60	450	4.0	740	Straight pipe with welded mid flange connection to division.
RM INOXPRES Type D1 Stainless Steel	108mm	A-60	450	10.5	940	Straight pipe with welded mid flange connection to division.



Lloyd's
Register

Lloyd's Register Verification Limited

71 Fenchurch Street, London, EC3M 4BS

Telephone 020 7423 2416 Fax 020 7423 2053

Email med@lr.org

Page 4 of 4
Document number MED 1650182
Issue number 1

DESIGN APPRAISAL DOCUMENT

Date 13 July 2016	Quote this reference on all future communications SOUTSO/SFS/TA/TR/MF/WP25988771
----------------------	---

ATTACHMENT TO EC TYPE EXAMINATION (MODULE B) CERTIFICATE No. MED 1650182

PLACE OF PRODUCTION

Raccorderie Metalliche S.p.A
Strada sabbionetana 59
46010 Campitello di Marcara (MN)
Italy



Martin Farrier
Lead Specialist
Statutory Fire & Safety
Southampton Technical Support Office, Marine & Offshore
For and on behalf of Lloyd's Register Verification
LRV EC Distinguishing No. 0038